

Sampling Date	PFOA ng/l	PFOS ng/l	GenX ng/l	PFBS ng/l	PFHxS ng/l	PFNA ng/l	Comments
2Q 2017 Well 5	63 ng/l						Chemours Sampling
2Q 2017 Well 6	70 ng/l						Chemours Sampling
2Q 2017 Entry Point	16 ng/l						Chemours Sampling
3Q 2017 Well 5	55 ng/l						Chemours Sampling
3Q 2017 Well 6	62 ng/l						Chemours Sampling
3Q 2017 Entry Point	13 ng/l						Chemours Sampling
4Q 2017 Well 5	55 ng/l						Chemours Sampling
4Q 2017 Well 6	59 ng/l						Chemours Sampling
4Q 2017 Entry Point	13 ng/l						Chemours Sampling
3Q 2018 Well 5	47 ng/l						Chemours Sampling
3Q 2018 Well 6	57 ng/l						Chemours Sampling
3Q 2018 Entry Point	13 ng/l						Chemours Sampling
3Q 2019 Well 5	60 ng/l						Chemours Sampling
3Q 2019 Well 6	58 ng/l						Chemours Sampling
3Q 2019 Entry Point	16 ng/l						Chemours Sampling
3Q 2020 Well 5	66 ng/l						Chemours Sampling
3Q 2020 Well 6	63 ng/l						Chemours Sampling
3Q 2020 Entry Point	15 ng/l						Chemours Sampling
3Q 2020 Entry Point	12 ng/l	<5 ng/l	<25 ng/l	<5 ng/l	<5 ng/l	<5 ng/l	EPA Sampling
3Q 2020 Raw Water	46 ng/l	<5 ng/l	<25 ng/l	9.1 ng/l	10 ng/l	<5 ng/l	EPA Sampling
4Q 2020 Entry Point	11 ng/l	<5 ng/l	<25 ng/l	<5 ng/l	<5 ng/l	<5 ng/l	EPA Sampling
1Q 2021 Entry Point	12.3 ng/l	<5 ng/l	<25 ng/l	<5 ng/l	<5 ng/l	<5 ng/l	EPA Sampling
2Q 2021 Entry Point	21.5 ng/l	<5 ng/l	<25 ng/l	<5 ng/l	<5 ng/l	<5 ng/l	EPA Sampling
Sampling Date	PFOA ng/l	PFOS ng/l	GenX ng/l	PFBS ng/l	PFHxS ng/l	PFNA ng/l	Comments
1Q 2023 Well 5	63.1 ng/l	<5 ng/l	<25 ng/l	9.99 ng/l	10.9 ng/l	<5 ng/l	Microbac Labs

1Q 2023 Well 6	63.2 ng/l	< 5 ng/l	<25 ng/l	12.9 ng/l	17.2 ng/l	12.6 ng/l		
1Q 2023 Entry Point	15 ng/l	< 5 ng/l	<25 ng/l	2.63 ng/l	3.72 ng/l	< 5 ng/l		
2Q 2023 Entry Point	13.6 ng/l	< 5 ng/l		<5 ng/l	3.5 ng/l	<5 ng/l		UCMR 5 Sampling
3Q 2023 Pilot influent	58 ng/l	< 5 ng/l		8.79 ng/l	11.8 ng/l	< 5 ng/l		Microbac Labs
3Q 2023 Pilot Effluent		<5 ng/l	<25 ng/l	<5 ng/l	<5 ng/l	<5 ng/l		Microbac Labs
3Q 2023 Entry Point	16.9 ng/l	< 5 ng/l	<25 ng/l	<5 ng/l	3 ng/l	<5 ng/l		UCMR 5 Sampling
3Q 2023 Well 5	50.7 ng/l	<5 ng/l		6.7 ng/l	9.0 ng/l	< 5 ng/l		Microbac Labs UCMR 5
3Q 2023 Well 6	52.5 ng/l	< 5 ng/l		8.9 ng/l	8.7 ng/l	< 5 ng/l		Microbac Labs UCMR 5
3Q 2023 Pilot Effluent		<5 ng/l	<25 ng/l	<5 ng/l	<5 ng/l	<5 ng/l		Microbac Labs UCMR5
4Q 2023 Pilot Influent	54.8 ng/l	< 5 ng/l		7.50 ng/l	5.59 ng/l	2.08 ng/l		
4Q 2023 Pilot Effluent	< 5 ng/l	<5 ng/l	<25 ng/l	<5 ng/l	<5 ng/l	<5 ng/l		Microbac Labs
1Q 2024 Pilot Effluent	< 5 ng/l	<5 ng/l	<25 ng/l	<5 ng/l	<5 ng/l	<5 ng/l		Microbac Labs